



PROJECT:

**Merced College -
Merced College - Fascia Tile Replacement**
3600 M Street, Merced, CA

Date : 05/23/2022

TETER Project No.: A 21-12275 D

CLIENT:

Merced Community College District
3600 M Street, Merced, CA
Merced Community College District

Client Project No.: 2022-09
DSA File No.: N/A
DSA Appl. No.: N/A

The following additions, deletions and revisions to the plans, specifications and Addenda shall become a part of the plans and specifications. It is the responsibility of the General Contractor to submit the information contained in this addendum to all subcontractors and suppliers. The Bidder shall acknowledge receipt of the Addendum in the Bid Proposal. (Addendum number of pages: 1 total page).

PROJECT MANUAL:

- 1 – 01: CONSTRUCTION DOCUMENTS, SHEET A800, DETAILS 4, 8 & 16**
REMOVE AND REPLACE BOTTOM CLOSURE PANEL NOTE AS STATED:
- A. REMOVE: **NEW BOTTOM CLOSURE PANEL, ATTACH TO (E) BLOCKING, TYP.**
 - B. REPLACE WITH: **NEW BOTTOM CLOSURE PANEL w/ 1/8" DIA. WEEP HOLES AT 12" O.C. MIN, ATTACH TO (E) BLOCKING, TYP.**

END OF ADDENDUM NO. 03

Jamie Hickman
Architect of Record